


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 27/06/2025


It is certified that an inspection team headed by HARISH KUMAR SAINI, IAS(Name of Officers with designation) from PHED, BANDIKUI(Name of Department/ Office) inspected the Euphoria twenty first century school, Bandikui(Name & Address of the school) on 25/06/2025 (date of inspection) and found that the Euphoria twenty first century school (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of One yearSignature with Seal: Name अवेशाबी अभियन्ताDesignation जन स्वास्थ्य अभियांत्रिकी विभाग
खण्ड बांदीकुई

Name & Address of the Office / Department :

To

Euphoria twenty first century school
Near Ganesh temple, Akhaneri road, Bandikui
Dist, Dausa (Rajasthan)
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


PRINCIPAL
EUPHORIA TWENTY FIRST
CENTURY SCHOOL, BANDIKUI

OFFICE OF THE JUNIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, DAUSA

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Jr. Chem./Dausa/2025-26/215-16

Date 6/2/2026

To,
M/S Euphoria Twenty First Century
School,
Near Ganesh Temple, Abhaneri Road,
Bandikui

The Sample was not Collected
by this laboratory Staff

**Not Valid for Water
Quality Legal Cases**

Tehsil


Dausa


Reference: Your Letter No. NM, dt. 04.02.2026

Particulars	Source		TW
	Location		
Block			Bandikui
Village/Town			Bacchi ka Bas
Date of Collection			04.02.2026
Date of receipt			04.02.2026
Date of Examination			06.02.2026
Private Chemical Sample No.			P-63
	Permission value as per I.S.:10500/2012		
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	
1. pH	6.5-8.5	6.5-8.5	7.9
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen Units)	5	15	None
4. Odour	Un Objectionable		U.O.
5. Total Alkalinity (as CaCO ₃) mg/l	200	600	330
6. Total Hardness (as CaCO ₃) mg/l	200	600	450
7. Calcium Hardness			210
8. Calcium (as Ca) mg/l	75	200	84
9. Magnesium Hardness			240
10. Magnesium (as Mg) mg/l	30	100	58
11. Chloride (as Cl ⁻) mg/l	250	1000	430
12. Nitrate (as NO ₃ ⁻) mg/l	45	45	45
13. Sulphate (as SO ₄ ⁻²) mg/l	200	400	-
14. Fluoride mg/l	1.0	1.5	0.71
15. Total Dissolve Solids mg/l	500	2000	1660
16. Residual Chlorine	0.2	1.5	Nil

Note:- Report is not valid for food licence and any certificate.

No: Lab/Jr. Chem./Dausa/2025-26/
Copy to:-
1. Chief Chemist, PHED Raj, Jaipur


PRINCIPAL
EUPHORIA TWENTY FIRST
CENTURY SCHOOL, BANDIKUI


Junior Chemist
P.H.E.D. Laboratory, Dausa

Date

Junior Chemist
P.H.E.D. Laboratory, Dausa

Office of the Junior Chemist
PUBLIC HEALTH ENGINEERING DEPTT. LABORATORY
Collectorate Circle, Khan Bhankhari Road, Dausa (Raj.)

No: Lab/Jr. Chem./Dausa/2025-26/ 817-18

Dated: 6/2/2026

Report of The Bacteriological Examination of Water

To
M/S Euphoria Twenty First Century
School,
Near Ganesh Temple, Abhaneri Road,
Bandikui

District Dausa


Tehsil: Sanganer

Reference Your Letter No.

NM

Dated 04.02.2026

S.No.	Private Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine mg/l	Source	Particulars of Samples	Coliform MPN/100 ml
1	B-61	04.02.2026	04.02.2026	-	TW	M/S Euphoria Twenty First Century School, Near Ganesh Temple, Abhaneri Road	Nil


Junior Chemist

PHED, Laboratory, Dausa


Dated:

No: Lab/Jr. Chem./Dausa/2025-26/

Copy to :-

1- The Chief Chemist, PHED Raj., Jaipur.

Junior Chemist
PHED, Laboratory, Dausa


PRINCIPAL
EUPHORIA TWENTY FIRST
CENTURY SCHOOL, BANDIKUI